

Can we use general fill to achieve the drainage swale shown behind the subject building?

All site grading should involve stripping existing crushed stone base material, shaping/grading with general fill, and replacement of min. 8" of crushed stone base.

Existing base material may be reused.